

Emission Test Certificate

Friday, July 22nd, 2011

Supplier: Albedor Industries (7-9 Research Drive, Croydon South, VIC 3136)

Sample Description: Albedor Ultra Finish: Gloss White

Date Tested: May 2011

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<p>Green Building Council of Australia GreenStar Office Design IEQ 13 GreenStar Office Design IEQ 14</p>	<p>Albedor Ultra Finish: Gloss White</p>
<p>Formaldehyde $\leq 0.12 \text{ mg/m}^3$</p>	<p>$<0.002 \text{ mg/m}^2/\text{hr}$ $\leq 0.005 \text{ mg/m}^3$</p>
<p>Total Volatile Organic Compounds $\leq 0.5 \text{ mg/m}^2/\text{hr}$ (24 hours)</p>	<p>$<0.001 \text{ mg/m}^2/\text{hr}$</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV110518