

Emission Test Certificate

Wednesday, April 17th 2013

Supplier: Albedor Industries (7-9 Research Drv, Croydon South, VIC 3136)

Sample Description: Albedor Thermoformed Gloss White Panel

Date Tested: March 2013

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<p>Specification</p> <p>Green Building Council of Australia Green Star Office Interiors V1.1 IEQ-11</p>	<p>Albedor Thermoformed Gloss White Panel</p>
<p>Total Volatile Organic Compound emission rate <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound emission rate 0.032 mg/m²/hr</p>
<p>Green Building Council of Australia Green Star Office Interiors V1.1 IEQ-14</p>	<p>Albedor Thermoformed Gloss White Panel</p>
<p>Formaldehyde emission rate <0.1 mg/m²/hr</p>	<p>Formaldehyde emission rate <0.002 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130319